



NOTES:

1. PLACEMENT OF STORM DRAIN BOXES DETERMINED BY STORM WATER DRAINAGE REPORT PREPARED BY A UTAH LICENSED PROFESSIONAL CIVIL ENGINEER. SPACING OF BOXES NOT TO EXCEED 500 FT.
2. CROSS WALK STRIPING AND SIGNING PLACEMENT ACCORDING TO M.U.T.C.D.
3. THE CITY ENGINEER MAY APPROVE SPECIFIC DESIGNS WHEN VARIATIONS FROM THE STANDARDS ARE NEEDED DUE TO SITE CONDITIONS, UTILITY, OR TOPOGRAPHICAL CONSTRAINTS. ANY VARIANT OF THESE DETAILS MUST BE BASED UPON A DESIGN STAMPED BY A UTAH LICENSED PROFESSIONAL CIVIL ENGINEER.



City of Bluffdale
Engineering Standards

Approved *Michael Fox* *June 13*
City Engineer Date

STANDARD DETAIL TITLE

TYPICAL UTILITY PLACEMENT

DETAIL SERIES:
STREET

DETAIL NO
ST-6A