



NOTES:

1. INSPECTION: METER BOX AND SERVICE LINE SHALL BE INSPECTED BY CITY PRIOR TO BACKFILLING.
2. BACKFILL: INSTALL BACKFILL IN LIFTS NOT EXCEEDING 8" AFTER COMPACTION. COMPACT EACH LIFT 96% (ASTM D-1557).
3. WATER METER SHALL BE PURCHASED FROM AND SET BY THE CITY.
4. METERS BOXES ARE NOT ALLOWED IN TRAFFIC AREAS.
5. PLACEMENT: ALL METERS ARE TO BE INSTALLED IN THE PARK STRIP OR WITHIN 7 FEET OF THE PROPERTY LINE (STREET SIDE) AND MUST BE PLACED NEAR MIDPOINT OF THE LOT AND MUST NOT BE LOCATED IN A DRIVEWAY, OR IN A SIDEWALK.

**BLUFFDALE
CITY**

**2" Culinary Water
Service**

February 2005
PAGE NO. W-4